

BINMALEY WATER DISTRICT
Binmaley, Pangasinan
Telefax: (075)540-0054; Tel.Nos: (075)540-0057 to 58
Email-Address : biwad_79@yahoo.com

BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL / BID BULLETIN No. 1

Date : September 14, 2020

SUBJECT: Design and Build of 500 Cu. M. Steel Ground Reservoir with Booster (1+1) and Pump Station and other Appurtenances at Brgy. Naguilayan, Binmaley, Pangasinan.


In accordance with Section 22.5.2 of IRR of R.A. No. 9184, this supplemental/bid bulletin No. 1 is hereby issued to clarify, modify or amend items in the Bid Documents as stated below:

ORIGINAL PROVISION	CLARIFICATION/AMENDMENT
<p><u>Section VI. SPECIFICATIONS</u></p> <p>TERMS OF REFERENCE</p> <p>7. b) Motor Control Center (MCC) – One (1) unit Variable Frequency Drive (VFD), 3 phase, 230 vols, 60 housed in explosion proof NEMA Enclosure (Grundfos Brand)</p>	<p><u>Section VI. SPECIFICATIONS</u></p> <p>TERMS OF REFERENCE</p> <p>7. b) Motor Control Center (MCC) – Two (2) units Variable Frequency Drive (VFD), 3 phase, 230 vols, 60 housed in explosion proof NEMA Enclosure (Grundfos Brand)</p>


Amendments/Inclusions/Clarifications made herein shall be construed as an integral part of the Bidding Documents.

For guidance and information of all concerned.

Prepared by:


MARY VIRGINIA A. AGUSTIN
Secretariat, BAC

Checked by:


JACQUELINE F. TERRADO
Chairperson/BAC