



Binmaley Water District

Luna St., Binmaley, Pangasinan

website: binmaleywaterdistrict.gov.ph

e-mail address: biwad_79@yahoo.com

Telefax: (075)540-0054; Tel.Nos. (075)540-0057 to 58

BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL/ BID BULLETIN No. 2

Date: September 16, 2020

Subject: Design and Build of 500 Cu.M. Steel Ground Reservoir with Booster (1+1) and Pump Station and Other Appurtenances at Brgy. Naguilayan, Binmaley, Pangasinan.

In accordance with Section 22.5.2 of IRR of R.A. No. 9184, this supplemental/ bid bulletin **No. 2** is hereby issued to clarify, modify or amend items in the Bid Documents Section VI. Specifications, Terms of Reference, as stated below:

Additional Terms of Reference:

TECHNICAL SPECIFICATIONS:

1. STEEL TANK

500 cubic meter capacity

➤ Based on the capacity of our pump at Naguilayan PS which is 80 cu.m./hr

- ❖ INLET size- 150mm- 6"
 - ❖ OUTLET size- 200mm- 8"
 - ❖ DRAIN- 200mm- 8"
 - ❖ OVERFLOW- 200mm – 8"
- *these are all flange type

- ❖ AIR VENT- used to aerate
- 2 air vents- 150mm- 6"
- ❖ LADDER (INSIDE)- 1 Hot dip galvanized iron (monkey type)
- ❖ LADDER (OUTSIDE)- with landing
- ❖ MANHOLE- 80cm
- ❖ DIAMETER OF TANK- 10 meters with concrete base 12 meters
HEIGHT- 6.5 meters

2. TANK OPERATION

- ❖ Combination of "Fill and Draw" and "Float" System
- Minimum Discharge Pressure- 45 psi
- Q- 100 cu.m./hr

3. BOOSTER PUMP SYSTEM

- ❖ 2 Booster Pump- 20 HP
- ❖ 2 Variable Frequency Drive




Binmaley Water District

Luna St., Binmaley, Pangasinan
website: binmaleywaterdistrict.gov.ph
e-mail address: biwad_79@yahoo.com
Telefax: (075)540-0054; Tel.Nos. (075)540-0057 to 58


Amendments/ Inclusions/ Clarifications made herein shall be construed as an integral part of the Bidding Documents.

For guidance and information of all concerned.

Prepared by:


MARY VIRGINIA A. AGUSTIN
Secretariat, BAC

Checked by:


JACQUELINE F. TERRADO
Chairperson, BAC